

DECLARATION *of* CONFORMITY

We, Schneider Electric Buildings, LLC, declare under our sole responsibility that our product (or product family) listed below conforms to Pressure Equipment Directive (PED 97/23/EC).

A. Description of the manufactured pressure equipment:

Two-way ball valves:

VB200R-15BS	VB210R-1SBS0S	VB210R-15BS09	VB210R-15BS04
VB200R-20BS	VB210R-15BS07	VB210R-20BS08	VB210R-1SBS09
VB210R-15BS03	VB210R-15BS08	VB210R-20BS09	VB210R-15BS01

Three-way ball valves:

VB300R-15BS	VB310R-15BS09	VB310R-15BS08	VB310R-15BS07
VB300R-20BS	VB310R-20BS08	VB310R-15BS03	
VB310R-15BS04	VB310R-20BS09	VB310R-15BS0S	

B. Assessment procedure of the compliance used:

- Category & Module: Category: Article 3, paragraph 3
Module: Sound Engineering Practice (SEP)
- Design Pressure min/max: 8.9 Bar working max., 41 Bar static pressure tested.
- Design Temperature range: 0..7 to 121 °C
- Medium: Non Dangerous liquid, Group 2
- Size: Less than ON 100

C. Standards referenced but not limited to:

- EN 736-1 Part 1, Definition of types of valves.
- EN 736-2 Part 2, Definition of components of valves.
- En 736-3 Part 3, Definition of terms.
- ANSI-FCI 70-2-2006 Control valve seat leakage standard.

For the above pressure equipment mentioned in A, we declare that this pressure equipment satisfies Directive PED 97/23/EC. 2013/53/EC.

Authorised By (" ")
Representative of Marketing
Schneider Electric, Buildings Business