Data Sheet | Item Number: 2273-205 PUSH WIRE® splicing connector; for solid conductors; max. 2.5 mm²; 5-conductor; transparent housing; yellow cover; Surrounding air temperature: max 60°C (T60); 2,50 mm²; transparent



https://www.wago.com/2273-205



Color: 🗌 transparent

Advantages:

- Convenient wiring via extremely compact design
- Push-in termination of up to eight solid conductors
- Cross-section range: 0.5 ... 2.5 mm²
- Any combination of conductor sizes is possible
- PUSH WIRE® connection terminates solid ("s") copper conductors

Notes

Safety management note

NOTICE: Observe installation and safety instructions!

- Only to be used by electricians!
- Do not work under voltage/load!
- Use only for proper use!

Dimensions in mm

- Observe national regulations/standards/guidelines!
- Observe technical specifications for the products!
- Observe the number of permissible potentials!
- Do not use damaged/dirty components!
- Observe conductor types, cross-sections and strip lengths!
- Insert conductor until it hits the product's backstop!
 Use original accessories!

Safety Information

To be sold only with installation instructions!

in grounded power lines

Electrical data							
Ratings per	IE	C/EN 6099	98	Approvals per		UL 486C	
Overvoltage category	Ш	III	Ш	Use group	В	С	D
Pollution degree	3	2	2	Rated voltage	-	-	-
Nominal voltage	-	-	450 V	Rated current	-	-	-
Rated surge voltage	-	-	4 kV				
Rated current	-	-	24 A				

Data Sheet | Item Number: 2273-205 https://www.wago.com/2273-205



Connection data			
Clamping units	5	Connection 1	
Total number of potentials	1	Connection technology	PUSH WIRE®
		Actuation type	Push-in
		Connectable conductor materials	Copper Aluminum
		Connectable conductor materials (note)	Terminating Aluminum Conductors WAGO Spring-Clamp Terminal Blocks are suitable for solid aluminum conductors up to 4 mm²/12 AWG if WAGO "Alu-Plus" Contact Paste <u>249-130</u> is used for ter- mination.
			"Alu-Plus" Contact Paste Advantages:
			 Automatically destroys the oxide film during clamping. Prevents fresh oxidation at the clam- ping point. Prevents electrolytic corrosion bet- ween aluminum and copper conductors (in the same terminal block). Provides long-term protection against corrosion.
			For spring pressure connections with PU- SH WIRE® connection technology, WAGO recommends that the aluminum con- ductor first be cleaned and then imme- diately inserted into the clamping unit fil- led with "Alu-Plus" contact paste.
			It is also possible to apply WAGO "Alu- Plus" additionally on the whole surface of the aluminum conductor before termi- nation.
			Please note that the nominal currents must be adapted to the reduced conduc- tivity of the aluminum conductors:: 2.5 mm ² = 16 A 4 mm ² = 22 A
		Solid conductor	0.5 2.5 mm² / 20 16 AWG
		Strip length	11 mm / 0.43 inches
		Wiring direction	Side-entry wiring

Physical data	
Width	22 mm / 0.866 inches
Height	5.8 mm / 0.228 inches
Depth	16.7 mm / 0.657 inches

Μ	ate	ria	l d	ata
111	alc	71 IQ	n u	alc

Information on material specifications can be found here	
transparent	
yellow	
Illa	
Polycarbonate (PC)	
V2	
Chrome-nickel spring steel (CrNi)	
Electrolytic copper (E _{cu})	
Tin	
0.039 MJ	
1.6 g	

Data Sheet | Item Number: 2273-205

https://www.wago.com/2273-205



Environmental requirements		
Ambient temperature (operation)	+60 °C	
Continuous operating temperature	105 °C	
Temperature marking per EN 60998	T60	

Commercial data	
Product Group	7 (Push Wire Conn.)
eCl@ss 10.0	27-14-11-04
eCl@ss 9.0	27-14-11-04
ETIM 9.0	EC000446
ETIM 8.0	EC000446
PU (SPU)	1000 (100) pcs
Packaging type	Box
Country of origin	DE
GTIN	4050821027874
Customs tariff number	85369010000

Environmental Product Compliance

RoHS Compliance Status

Compliant,No Exemption

Approvals / Certificates

General approvals

	\wedge
LISTED	(VDE)
ALCONNECTOR	(VDE)

Approval	Standard	Certificate Name
cULus_Listed_667F Underwriters Laboratories Inc.	UL 486C	E69654
VDE VDE Prüf- und Zertifizie- rungsinstitut	EN 60998	40029794

Declarations of conformity and manufacturer's declarations

Approval	Standard	Certificate Name
EU-Declaration of Confor- mity WAGO GmbH & Co. KG	-	-
UK-Declaration of Confor- mity WAGO GmbH & Co. KG	-	-

Approvals for marine applications

Approval	Standard	Certificate Name
ABS American Bureau of Ship- ping	-	15-HG1419918-PDA
DNV GL Det Norske Veritas, Ger- manischer Lloyd	EN 60998	TAE000015T
LR Lloyds Register	EN 60998	LR22207029TA

Data Sheet | Item Number: 2273-205

https://www.wago.com/2273-205



Downloads
Environmental Product Compliance
Compliance Search
Environmental Product Compliance 2273-205

Documentation

Bid Text			
2273-205	19.02.2019	xml 3.17 KB	$\underline{\checkmark}$
2273-205	17.05.2017	doc 24.50 KB	\downarrow
ausschreiben.de 2273-205			\downarrow

CAD/CAE-Data

CAD data	
2D/3D Models 2273-205	\downarrow

CAE data	
EPLAN Data Portal 2273-205	$\underline{\downarrow}$
WSCAD Universe 2273-205	\downarrow
ZUKEN Portal 2273-205	$\underline{\downarrow}$

1 Compatible Products

1.1 Optional Accessories

1.1.1 Mounting adapter

1.1.1.1 Mounting accessories



Item No.: 2273-500 Mounting carrier; for single- and doublerow con.; 2273 Series; for DIN-35 rail mounting/screw mounting; orange

Data Sheet | Item Number: 2273-205

https://www.wago.com/2273-205

1.1.2 Tool

1.1.2.1 "Alu-Plus" contact paste



Item No.: 249-130 Syringe; Contents: 20 ml Alu-Plus contact paste

Installation Notes

Conductor termination





Strip solid conductor to 11 mm/0.43 inch (see marking).

The transparent housing shows if conductors are fully inserted; within the colored base, a clear port shows if the conductor's strip length is correct. Conductors are correctly stripped if the clear port shows no bare conductor on the unprinted connector side. Picture shows center conductor with exceeded strip length.



Termination: Insert the stripped solid conductor until it hits the backstop.



Removal: Hold conductor to be removed and twist alternately left and right while pulling the connector.

Testing



Testing via test port opposite to conductor entry.

Subject to changes. Please also observe the further product documentation!