


PRODUCT-DETAILS

XT3S 250 MA200 Im=1200...2400 3p F F

XT3S 250 MA200 Im=1200...2400 3p F F



General Information

Extended Product Type	XT3S 250 MA200 Im=1200...2400 3p F F
Product ID	1SDA068282R1
EAN	8015644021887
Catalog Description	XT3S 250 MA200 Im=1200...2400 3p F F
Long Description	C.BREAKER TMAX XT3S 250 FIXED THREE-POLE WITH FRONT TERMINALS AND MAGNETIC RELEASE MA Iu 200 A I3=1200...2400 A

ABB EcoSolutions

ABB EcoSolutions	Yes
------------------	-----

Circular Value

Circular Design Principles Recyclability Rate	Design for Closing Resource Loops - Standard EN45555 - 60.5 %
Conflict Minerals Reporting Template (CMRT)	9AKK108467A5658
End of Life Instructions	9AKK108468A2350
Group Waste to Landfill	UL 2799 Zero Waste To Landfill Validation available

Target

Toxic Substances Control Act - TSCA	9AKK108467A8326
-------------------------------------	-----------------

Eco Transparency

Environmental Product Declaration - EPD	9AKK108468A2294
---	-----------------

Environmental

Environmental Information	9AKK107991A8215 9AKK108467A6707
REACH Declaration	9AKK108466A1425
RoHS Information	9AKK108466A1424
RoHS Status	Following EU Directive 2011/65/EU and Amendment 2015/863 July 22, 2019

Ordering

Order Code US and Canada	XT3SE3200MFF000XXX
EAN	8015644021887
Minimum Order Quantity	1 piece
Customs Tariff Number	85362090

Dimensions

Product Net Width	105 mm
Product Net Height	150 mm
Product Net Depth / Length	70 mm
Product Net Weight	1.7 kg

Container Information

Package Level 1 Units	box 1 piece
Package Level 1 Width	150 mm
Package Level 1 Height	190 mm
Package Level 1 Depth / Length	155 mm
Package Level 1 Gross Weight	1.7 kg
Package Level 1 EAN	8015644021887

Additional Information

Circuit Breaker Type to be Associated	Motor Protection
---------------------------------------	------------------

Connecting Capacity Main Circuit	Busbar 85..192 mm ²
Current Type	AC/DC
Electrical Durability	120 cycles per hour 8000 cycle
Mechanical Durability	240 cycles per hour 25000 cycle
Number of Poles	3
Opening Time	CB with SOR 15 ms CB with UVR 15 ms
Order Multiple	1 piece
Power Loss	at Rated Operating Conditions per Pole 13.2 W
Product Main Type	SACE Tmax XT
Product Name	Moulded Case Circuit Breaker
Product Type	Automatic Circuit Breaker
Rated Current (I_n)	200 A
Rated Frequency (f)	50 / 60 Hz
Rated Voltage (U_r)	690 V
Rated Impulse Withstand Voltage (U_{imp})	8 kV
Rated Instantaneous Short-Circuit Current Setting (I_s)	1200...2400 A
Rated Insulation Voltage (U_i)	800 V
Rated Operational Voltage	690 V AC 500 V DC
Rated Service Short-Circuit Breaking Capacity (I_{cs})	(220 V AC) 42.5 kA (230 V AC) 42.5 kA (240 V AC) 42.5 kA (380 V AC) 27 kA (415 V AC) 27 kA (440 V AC) 20 kA (500 V AC) 15 kA (525 V AC) 10 kA (690 V AC) 3 kA (250 V DC) 2 Poles in Series 27 kA (500 V DC) 3 Poles in Series 37.5 kA
Rated Ultimate Short-Circuit Breaking Capacity (I_{cu})	(220 V AC) 85 kA (230 V AC) 85 kA (240 V AC) 85 kA (380 V AC) 50 kA (415 V AC) 50 kA (440 V AC) 40 kA (500 V AC) 30 kA (525 V AC) 20 kA (690 V AC) 6 kA (250 V DC) 2 Poles in Series 36 kA (500 V DC) 3 Poles in Series 50 kA
Rated Uninterrupted Current (I_u)	250 A
Recommended Screw Driver	Main Circuit M8
Release	MA
Release Type	M
Short-Circuit Performance	S

Level	
Standards	IEC
Sub-type	XT3
Terminal Connection Type	Front
Terminal Type	Bolt
Tightening Torque	8 N·m
Version	F
CAD Dimensional Drawing	1SDH001295R0409

Certificates and Declarations

ATEX Certificate	No certification needed
Data Sheet, Technical Information	1SDC210100D0206 1SDC210099D0206
Declaration of Conformity - CE	9AKK106713A5530
GL Certificate	1SDL000163R0094
LR Certificate	1SDL000163R0100
UL Certificate	No certification needed
VDE Certificate	No certification needed
Dimension Diagram	1SDH000720R0100
Mechanical Drawings	1SDH000720R0100
Wiring Diagram	1SDM000068R0001
Instructions and Manuals	1SDH000720R0001

Classifications

ETIM 7	EC000228 - Power circuit-breaker for trafo/generator/installation protection
ETIM 8	EC000228 - Power circuit-breaker for trafo/generator/installation protection
ETIM 9	EC000228 - Power circuit-breaker for trafo/generator/installation protection
Object Classification Code	Q
UNSPSC	39120000
WEEE Category	5. Small Equipment (No External Dimension More Than 50 cm)
eClass	V11.1 : 27370409

Categories

Low Voltage Products and Systems → Circuit Breakers → Moulded Case Circuit Breakers → Tmax XT

