

DECLARATION OF CONFORMITY

No. S.CE/EN/0275/V2/2013/204

**KANLUX S.A., ul. Objazdowa 1-3, 41-922 Radzionków (POLAND)**

herewith declares that the product:

CEILING LIGHTING POINT FITTINGType / types: (1) **TESON AL-DSL50**, (2) **TESON AL-DSO50**,
(3) **TESON AL-DTL50**, (4) **TESON AL-DTO50**Trade mark: **Kanlux**

Basic parameters: 220-240V~, 50/60Hz; Class I; IP20; JDR, GU10: (1)(2) - max.35W; (3)(4) - max.50W

is in conformity with the provisions of the following EC directive(s)
(including all applicable amendments):**Directive (LVD) – 2006/95/EC****Directive (EMC) – 2004/108/EC****Directive (RoHS) – 2011/65/EC**references of standards and/or technical specifications applied for this declaration
of conformity:**EN 60598-1:2008 +A11:2009****EN 60598-2-2:2012****EN 55015:2006 +A1:2007 +A2:2009****EN 61547:2009****Additional information:**Kanlux S.A. has an implemented Quality Management system according to norm **ISO 9001:2008**
confirmed by ISO certificate PL8000069 issued by Bureau Veritas Certification Polska Sp. z o.o.Last two digits of the year in which the CE marking was affixed: **09****NWP/779; ID0275; S.CE/204****Radzionków, 11.06.2013**

Kanlux S.A.
Kierownik Działu Technicznego **Kanlux S.A.**
Specjalista ds. Wdrożenia i Certyfikacji Produktów
Dariusz Stańczyk Adam Wabnic

Kanlux S.A.
Kierownik Laboratorium Badawczego
Krzysztof Żurek

.....
name and function of the signatory